



Product Service

Attestation of Conformity

No. N8A 081002 0010 Rev. 01

Holder of Attestation: **Taizhou Guangxing Electronics Tech Co., Ltd**

Building 29, No.318 Chenguang Road, Wenling Eastern New Area
317511 Wenling
PEOPLE'S REPUBLIC OF CHINA

Product:

Pressure switches

Pressure control, automatic pump control

Model(s):

DPS-1, DPS-4, DPS-9

Parameters:

Rated voltage:	110VAC to 120VAC or 220VAC to 240VAC
Rated frequency:	50/60Hz
Rated current:	10A
Type of load:	Resistive
Maximum temperature of mounting surface:	T55
Number of cycles of automatic action:	10 000
Maximum working pressure:	1.0MPa (10bar)
Features of automatic action:	Type 1.B
Circuit disconnection:	Micro-disconnection
Degree of protection:	IP65 after mounted
Protection against electric shock:	Class I

Tested according to:

EN 60730-1:2016/A2:2022
EN 60730-2-6:2016/A1:2020

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704101944601-01

Date, 2023-07-14

(Hongbo Zhu)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

**TUV®**