


CERTIFICATE

Certificate holder	DIMAS Solar SA 2nd klm Argos-Nafplion 212 00 Argos GREECE
Production facility	Argos
Product	Solar collectors
Type, Model	SOL+EVO 19, SOL+EVO 20, SOL+EVO 23 SOL+EVO 25, SOL+EVO 27, SOL+EVO 29 TERRA+EVO 19, TERRA+EVO 20, TERRA+EVO 23 TERRA+EVO 25, TERRA+EVO 27, TERRA+EVO 29
Testing basis	DIN EN 12975-1:2011-01 DIN EN ISO 9806:2018-04 Solar KEYMARK Scheme Rules (2022-06)

Mark of conformity



Registration No. 011-7S1493 F

Valid until 2027-12-31

Right of use This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

ANNEX

Page 1 of 1

Certificate

011-7S1493 F dated 2023-01-16

Technical Data

See data sheet, part of the test report of 2022-12-20

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 14 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures or with appropriate frost protection controller.

**Testing laboratory/
Inspection body**

Universität Stuttgart
Institut für Gebäudeenergetik,
Thermotechnik und Energie-
speicherung
Pfaffenwaldring 6-6 a
70569 Stuttgart
GERMANY

Test report(s)

22COL1679, 22COL1681, 22COL1647Q/1 dated 2022-12-20

